


# Certificate of Fire Protection Works



**No. 822.2020**

**Argus Fire Protection Company Ltd**  
**Hendglade House**  
**46 New Bridge Road**  
**Stourbridge**  
**DY8 1PA**

**Priory Fields,**  
**Kettleby, Brigg**  
**Lincolnshire**  
**Tel: 01652 413110**

<b>Properties:</b> Westview Court Greenway Wythenshawe Manchester M22 4LT		<b>Tel:</b> 07785426299
		<b>Email:</b> <a href="mailto:k.winstanley@argusfire.co.uk">k.winstanley@argusfire.co.uk</a>
<b>Areas of application:</b>	Sprinkler system pipes.	
<b>Products applied:</b>	Firepro acoustic intumescent sealant.	
<b>Specifics:</b>	Fire stopping products have been applied to orange pipe breaches in boxing in on all floors.	
<b>Installers Details</b>		
<b>Name:</b> Steve Asquith	<b>Address:</b> Priory Fields Kettleby Brigg Lincolnshire DN20 9HN	<b>Tel:</b> 01652 413110
		<b>Email:</b> <a href="mailto:phil@flamehold.co.uk">phil@flamehold.co.uk</a>
<b>Company Name:</b> Flame Hold Ltd		<b>Qualification:</b> GIFireE , FPA Fire Risk Assessor & FIRAS Accreditation – Certificate No. FD5102; FIRAS ID – S69545
I/We hereby certify that the Passive Fire Protection products/systems, supplied for the above project have been supplied & fitted by Flame Hold Ltd. To the best of my knowledge and belief – based on the information supplied – to be the appropriate products/systems for the project to provide Passive Fire Protection to achieve 30 minute fire ratings.		
<b>Signature of Installer:</b> 		<b>Date:</b> 07.12.2020

**All Fire Prevention Measures should be checked annually and preventative maintenance carried out. Failure to do so may impair the performance.**